

SCH7

STORM CLASS™ LOUVER

Concealed Mullion Louv	ver Type SCH7
	Extruded Aluminum (Alloy 6063-T5)
Front Blade	0.081 in. (2.06 mm)
Back Blade	0.063 in. (1.60 mm)
Frame	0.081 in. (2.06 mm)
Louver Depth	7 in. (177.8 mm)
Free Area – 4 ft. x 4 ft.	Unit 8.44 sq. ft. (0.78 m ²)
Percent Free Area	52.8%
Free Area Velocity at Bo Point of Water Penetra 0.01 oz H ₂ O/sq. ft. Free	3 3
Air Volume Flow Rate a Beginning Point of Wat Penetration – 4 ft. x 4 f	

Point of Water Penetration 0.32 in. H₂O (0.080 kPa) **Wind-Driven Rain Water Penetration Data**

Exterior Wind Velocity. 29 mph (13 m/s) Rainfall Rate 3 in. (75 mm)/hour Effectiveness 99.2% Core Ventilation Rate 374 fpm (1.9 m/s)
Exterior Wind Velocity 50 mph (22 m/s) Rainfall Rate 8 in. (200 mm)/hour Effectiveness 98.2% Core Ventilation Rate 0 fpm (0.0 m/s)





RECOMMENDED SPECIFICATION

Pressure Drop at Beginning

GENERAL

Furnish and install where indicated on plans or described in schedules Storm Class™ Louver Type SCH7 as designed and manufactured by The Airolite Company LLC, Schofield, Wisconsin. Louvers shall be furnished with bird screen, insect screen, supports, installation hardware and finishes as specified and as required for a complete installation.

SUBMITTALS

Manufacturer shall submit shop drawings incorporating key plans, elevations, sections and details showing profiles, angles and spacing of louver blades and frames; unit dimensions related to wall openings and construction; and, anchorage details and locations. Submit theoretical calculations prepared by a professional engineer specializing in the application of welding technology demonstrating that each fillet weld joining blade and frame members will withstand a minimum of 526 pounds of force in shear. Provide samples of manufacturer's finish and color charts showing the full range of colors available. For each type of product specified, submit free area, air performance, water penetration and wind-driven rain ratings determined in accordance with AMCA Standard 500-L and licensed under the AMCA Certified Ratings Program.

PRODUCTS

Louvers shall be Storm Class™ type and rated to resist water penetration under wind-driven rain conditions. Louvers shall be 7-inches (177.8 mm) deep and assembled entirely from extruded aluminum components. Exterior blades and frames shall be 0.081-inch (2 mm) thick extruded aluminum, alloy 6063-T5. Interior blades shall be 0.063-inch (1.6 mm) extruded aluminum, alloy 6063-T5. Exterior blades shall be horizontal and spaced 4.5-inches (114.3 mm) on center.

OPTIONAL WELDED ASSEMBLY

Join stationary blade, head, sill and jamb frames with fillet welds concealed from view, unless the size of the louver makes screwed connections between louver sections necessary. Louver blades shall be joined to each jamb frame with fillet welds produced with the Pulsed Gas Metal Arc Welding (GMAW/Mig) process.

STRUCTURAL DESIGN CRITERIA

Manufacturer shall design and furnish all supports required to withstand a wind force of not less than 25 pounds per square foot. Louvers larger than 144-inches wide x 72-inches high or 72-inches wide x 144-inches high will be fabricated and installed in multiple sections. Louver blades, frames, mullions and anchorages shall be demonstrated to withstand the specified wind design load.

PERFORMANCE RATINGS

FREE AREA: 8.44 Square Feet (0.78 m²)

MINIMUM FREE AREA VELOCITY
at Beginning Point of Water Penetration: 948 fpm (4.82 m/s)

MINIMUM AIR VOLUME FLOW RATE
at Beginning Point of Water Penetration: 8,001 cfm (3.78 m³/s)

MAXIMUM STATIC PRESSURE
at Beginning Point of Water Penetration: 0.32 in. H,O (0.080 kPa)


See page 3 for complete Wind-driven Rain Performance See page 4 for complete finish options

LOUVER TYPE SCH7 PRODUCT DESCRIPTION & DETAILS

Airolite Storm ClassTM combination louvers are designed and rated to provide high volume intake and exhaust ventilation and the greatest level of protection against water penetration available even under the most severe wind-driven rain conditions. Airolite Storm ClassTM Combination louvers incorporate exterior and interior louver modules that afford the designer optimum flexibility in aesthetic, economic and performance considerations. The exterior module allows the designer to present a wide range of conventional to non-traditional appearances. The interior module incorporates a highly efficient horizontal blade profile that yields high ventilation rates and presents a formidable barrier to water penetration. Where there are large inactive louver areas, the interior module may be omitted to achieve economy. Louver Type SCH7 is a 7-inch (177.8 mm) deep louver rated to be 99.2% effective at a core area velocity of 374 fpm (1.9 m/s) when tested at a wind velocity of 29 mph (13 m/s) and 3-inch (75 ml) per hour rainfall rate. Airolite Storm ClassTM Louver Type SCH7 is a highly efficient louver with AMCA Licensed Air Performance, Water Penetration and Wind-driven Rain performance ratings that enable designers to select and specify this product with confidence. Please contact your local Airolite representative or the factory for assistance with the layout and design of support systems when required.

VERTICAL SECTION DETAIL

PLAN SECTION DETAIL




Minimum Section Size:

12 in. (30 cm) W x 12 in. (30 cm) H

Maximum Section Size:

144 in. (366 cm) W x 144 in. (366 cm) H
*one dimension cannot exceed 72 in

ACCESSORY ITEM





LOUVER TYPE SCH7 PERFORMANCE RATINGS

FREE AREA CHART - in square feet

NLL A			*** ·	- 111 30	quare	icet						
Louver	Louver Width in Inches											
Height Inches	12	24	36	48	60	72	84	96	108	120	132	144
12	0.29	0.67	1.06	1.44	1.83	2.21	2.45	2.83	3.22	3.60	3.99	4.37
24	0.72	1.69	2.66	3.62	4.59	5.55	6.15	7.11	8.08	9.05	10.01	10.98
36	1.21	2.82	4.43	6.04	7.65	9.27	10.26	11.87	13.48	15.09	16.70	18.31
48	1.69	3.94	6.19	8.44	10.69	12.94	14.32	16.58	18.83	21.08	23.33	25.58
60	2.12	4.96	7.79	10.62	13.45	16.28	18.02	20.86	23.69	26.52	29.35	32.18
72	2.61	6.09	9.56	13.04	16.52	20.00	22.13	25.61	29.09	32.57	36.04	39.52
84	3.09	7.20	11.32	15.44	19.55	23.67						
96	3.52	8.22	12.92	17.62	22.32	27.01						
108	4.01	9.35	14.69	20.04	25.38	30.73]					
120	4.49	10.47	16.45	22.44	28.42	34.40]					
132	4 92	11 49	18.05	24 62	31 18	37 74]					



The Airolite Company, LLC certifies that Louver Type SCH7 shown herein is licensed to bear the AMCA seal. The ratings shown are based on tests and procedures performed in accordance with AMCA

Publication 511 and comply with the requirements of the AMCA Certified Ratings Program. The AMCA Certified Ratings Seal applies to Water Penetration, Air Performance and Wind-driven Rain.

WATER PENETRATION

144

(Standard Air - .075 lb./ft.3; Test Size - 48 in. x 48 in.; Test Duration - 15 min.)

12.62 19.83 27.04 34.25 41.46

The AMCA Water Penetration Test provides a method for comparing various louver models and designs as to their efficiency in resisting the penetration of rainfall under specific laboratory test conditions. The beginning point of water penetration is defined as that velocity where the water penetration curve projects through 0.01 oz. of water (penetration) per sq. ft. of louver free area. These performance ratings do not guarantee a louver to be weather-proof or stormproof and should be used in combination with other factors including good engineering judgement in selecting louvers. *The beginning point of water penetration for Model SCH7 is 948 fpm (4.82 m/s) free area velocity.

WIND-DRIVEN RAIN PERFORMANCE


75mm/h (3 in/hr) Rainfall & 13 m/s (29 mph) Wind Velocity				200mm/h (8 in/hr) Rainfall & 22 m/s (50 mph) Wind Velocity			
Ventilation Air Core Velocity m/s (fpm)		Water Penetration Effectiveness %	Water Penetration Classification	Ventilation Air Core Velocity m/s (fpm)	Ventilation Air Free Area Velocity m/s (fpm)	Water Penetration Effectiveness %	Water Penetration Classification
0.0 (0)	0.0 (0)		А	0.0 (0)	0.0 (0)	98.2	В
0.5 (98)	0.9 (172)		А	0.5 (96)	0.9 (169)	96.4	В
1.0 (191)	1.7 (336)	99.9	А	0.9 (175)	1.6 (308)	93.9	С
1.2 (238)	2.1 (418)	99.8	А	1.4 (283)	2.5 (498)	90.1	С
1.9 (374)	3.3 (658)	99.2	Α	2.0 (386)	3.4 (679)	83.4	С
2.3 (457)	4.1 (804)	98.9	В	2.5 (496)	4.4 (872)	78.5	D
3.0 (586)	5.2 (1030)	95.6	В	2.9 (579)	5.2 (1018)	71.7	D
3.5 (685)	6.1 (1204)	92.4	С	3.5 (680)	6.1 (1196)	62	D
3.9 (773)	6.9 (1359)	90.1	С	4.0 (786)	7.0 (1382)	54.3	D
4.4 (861)	7.7 (1514)	88	С	4.5 (885)	7.9 (1556)	49.2	D
5.0 (984)	8.8 (1730)	80.2	С	4.9 (973)	8.7 (1711)	42.7	D

Discharge Loss Coefficient Class (Intake) = 3

Weather louvers shall be classified by their ability to reject simulated rain. The table to the right shows different classifications based on the maximum simulated rain penetration per square meter (square feet) of louver. Water penetration rating at a given louver face velocity is determined by the water penetration while the louver is subjected to a selected simulated rainfall rate and wind velocity.

AIRFLOW RESISTANCE

(Standard Air - .075 lb./ft.3)




Louver Type SCH7 resistance to airflow varies depending on louver application (air intake or air exhaust). Free area velocities (shown) are higher than the average velocity through the overall louver size. (Test Figure: 5.5-6.5)

Discharge Loss Coefficient Classifications					
Class	Discharge Loss Coefficient				
1	0.4 and Above				
2	0.3 to 0.399				
3	0.2 to 0.299				
4 0.199 and Below					

Wind-driven Rain Penetration Classes			
Class	Effectiveness		
Α	1 to 0.99		
В	0.989 to 0.95		
С	0.949 to 0.80		
D	Below 0.80		



LOUVER TYPE SCH7 METHOD OF INSTALLATION & ACCESSORY OPTIONS



FINISHES* (Select one of the following)

ACRYLIC ENAMEL: Louvers shall be cleaned, pretreated and Finished with an oven-cured thermosetting acrylic enamel finish that meets or exceeds the performance requirements of AAMA 2603, "Voluntary Specification Performance Requirements and Test Procedures for Pigmented Organic Coatings."

2-COAT FLUOROPOLYMER: Louvers shall be cleaned, pretreated and Finished with an inhibitive primer and oven-cured Kynar 500® / Hylar 5000® resin coating with minimum 1.2 mils dry-film coating thickness that meets or exceeds the performance requirements of AAMA 2605, "Voluntary Specification, Performance Requirements and Test Procedures for Superior Performance Organic Coatings on Aluminum Extrusions and Panels."

3-COAT FLUOROPOLYMER: Louvers shall be cleaned, pretreated and Finished with an inhibitive primer and oven-cured Kynar 500® / Hylar 5000® resin coating with minimum 2.0 mils dry-film coating thickness that meets or exceeds the performance requirements of AAMA 2605, "Voluntary Specification, Performance Requirements and Test Procedures for Superior Performance Organic Coatings on Aluminum Extrusions and Panels."

CLEAR ANODIZE: Louvers shall be Finished with a Class I clear anodized coating (AA-M10C22A41) that complies with the performance requirements of AAMA Specification 611-98, "Voluntary Specification for Anodized Architectural Aluminum."

COLOR ANODIZE: Louvers shall be Finished with a Class I electrolytically color anodized coating (AA-M10C22A42/44) that complies with the performance requirements of AAMA Specification 611-98, "Voluntary Specification for Anodized Architectural Aluminum." Color shall be (select one): Champagne, Light Bronze, Medium Bronze, Dark Bronze, Extra Dark Bronze or Black Anodize.

* Finish applied to exterior louver module only. Specify finish applied to interior louver module when required.



Copyright ©2018 The Airolite Company, LLC
The Airolite Company, LLC reserves the right

Submittal SCH7 March 2018